



MARTEL NO. 51326      CLIENT SAMPLE IDENTIFICATION 000001 DI SAMPLE PORT B      Sample Date/Time 10/23/2020 09:40

Compound	Test Value	Test Unit	Method	LOQ/PQL	Analysis Date/Time/Initial
Heterotrophic Plate Count	<1	cfu/ml	SM 9215 B-94	1	10/23/2020 15:08 MA
Total Coliform Bacteria by ONPG-MUG	absence	coli/100ml	SM 9223 B-04	1	10/23/2020 13:15 MA
Conductance (Specific)	<2	umhos/cm	SM 2510 B-97	2	10/26/2020 13:15 AE
Resistivity	<0.5	megohm/cm	EPA 120.1	0.5	10/26/2020 13:15 AE
Chloride	<1.0	mg/l	SM 4500-Cl E-97	1	11/04/2020 14:45 CSG
Dissolved Silica (SiO <sub>2</sub> )	3.4	mg/l	SM 4500SI-D	0.05	11/06/2020 07:45 CB
Sodium	<0.2	mg/l	EPA 200.8	0.2	11/13/2020 16:32 BJ

MARTEL NO. 51326      CLIENT SAMPLE IDENTIFICATION 001SUB DI SAMPLE PORT B- SUBBED OUT      Sample Date/Time 10/23/2020 09:40

Compound	Test Value	Test Unit	Method	LOQ/PQL	Analysis Date/Time/Initial
TOC (Total Organic Carbon)	See	Attached	SM 5310 B-00		10/31/2020 02:11 SUB

## Report of Analysis

Client Sample ID: 51326-1 TILLEY  
 Lab Sample ID: FA80192-4  
 Matrix: AQ - Water  
 Project: TOC

Date Sampled: 10/23/20  
 Date Received: 10/27/20  
 Percent Solids: n/a



### General Chemistry

Analyte	Result	RL	MDL	Units	DF	Analyzed By Method
Total Organic Carbon	0.23 U	1.0	0.23	mg/l	1	10/31/20 02:11 FN SM5310 B-11/SW9060A

RL = Reporting Limit  
 MDL = Method Detection Limit

U = Indicates a result < MDL  
 J = Indicates a result > = MDL but < RL



Page 3  
10/27/20